



## SECTION

NOT TO SCALE

### NOTES:

1. 8" PRV STATION SHOWN. 6" PRV STATION IS IDENTICAL EXCEPT THE UPSTREAM AND DOWNSTREAM PIPING, FITTINGS, AND VALVES ARE 6".
2. PAINT ALL EXPOSED PIPING AND FITTINGS WITHIN VAULT AND ABOVE GRADE.
3. ALL VALVES INSIDE VAULT TO HAVE HAND WHEEL OPERATORS.

APPROVED: SCOTT THOMASSON

REV. DATE: NOV. 01, 2005

WATER/WASTEWATER DIVISION



STANDARD DETAILS

6" AND 8" PRV STATION  
SECTION

FILE SD709A.DGN DRAWING NO. 709A